



MUNICIPAL CORPORATION CHANDIGARH

(Public Health Laboratory at Water Works Sector - 39)

TEST - REPORT

Not for legal use

Lab No. : MCPHL/25/1703

Date : 23.05.2025

Ref. No. : GMHS/22-C/1156	Sample Details	Date & Time
Dated : 19.05.2025		
Issued to : The Headmaster Govt. Model High School, Sector - 22, Chandigarh.	Collected By : Laboratory Staff	Laboratory Staff
Location : From School tap of Govt. Model High School, Sector - 22,C, Chandigarh.	Collection Date : 20.05.2025 at 7:10a.m	20.05.2025 at 7:10a.m
Packing : Polypropylene and glass bottle	Received at Lab : 09:15a.m.	09:15a.m.

Test Result (As Per BIS 10500:2012)

S.No	Examination	Quality Standard	Unit	Result
1	pH	6.5 - 8.5	---	7.73
2	Odour	Agreeable	---	Agreeable
3	Taste	Agreeable	---	Agreeable
4	Turbidity	<1	N.T.U.	0.8
5	Total Dissolved Solids	<500	mg/l	132
6	Residual Chlorine	0.2 - 0.4	mg/l	0.2
7	Total Alkalinity (as CaCO ₃)	<200	mg/l	86
8	Total Hardness (as CaCO ₃)	<200	mg/l	74
9	Chlorides (as Cl)	<250	mg/l	04
10	Free & Saline Ammonia	NIL	mg/l	NIL
11	M.P.N. of Coliform Bacteria / 100ml of water	Zero	M.P.N.	0 (Excellent)

Payment received vide receipt No. 05/2025-26/251269, dated 19.05.2025, amount Rs.-3300/-

Note:- Water sample is found "POTABLE"


Chemist,
M.C.P.H. Laboratory,
Chandigarh.


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Endst. No. MCPH/25/-----

Dated : 23.05.2025

Copy forwarded to the Medical Officer of Health Municipal Corporation, Sector -17, Chandigarh for Information please.


Chemist,
M.C.P.H. Laboratory,
Chandigarh.


Sub Divisional Engineer,
M.C.P.H. Sub Division No.1,
Chandigarh.

Remarks:-

- The results given above are related to the sample as collected and tested in lab.
- The test report can't be regenerated in whole or part there of without written permission of Competent Authority.
- The test report can't be used for any publicity or legal purpose.

----- End of Report -----

WATER IS LIFE, SAVE IT